



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511CS0347

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	IBP GmbH Theodor-Heuss-Straße 18, D-35440 Linden
Distributor <i>Vertreiber</i>	IBP GmbH Theodor-Heuss-Straße 18, D-35440 Linden
Product Category <i>Produktart</i>	installation systems and system joints (PN 10): pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	system connector as compression connector (type M-MM) made of stainless steel for pipes made of stainless steel according to DVGW GW 541
Model <i>Modell</i>	>B< Press Inox
Test Reports <i>Prüfberichte</i>	laboratory control test: from 30.06.2022 (TSZ) type testing: 1200005023 from 09.10.2017 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW CERT ZP 8500 (01.01.2017) UBA BWGL-Metalle (14.05.2020) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)

70029 04-A-DE

Date of Expiry / File No. 09.10.2027 / 22-0537-WNV
Ablaufdatum / Aktenzeichen

10.08.2022 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
>B< Press Inox	diameter: 76,1 mm	
>B< Press Inox	diameter: 88,9 mm	
>B< Press Inox	diameter: 108 mm	

certified Components***zertifizierte Bauteile / Werkstoffe***

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DW-5253BQ0577	Sealing material for drinking water installations	01/U70 EP/01/U70 EP	LAV.EL GOMMA S.r.l.
DW-5253BT0074	Sealing material for drinking water installations	TIMO 5-70/TIMO 5-70	Tecnogomma International S.p.A.

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

The test was made with tubes made of stainless steel according to DVGW-working sheet GW 541.

pressing contour for the connections up to \varnothing 54 mm: B
 pressing contour for the connections \varnothing 76,1 - 108 mm: M

