



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511CN0182

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	IBP GmbH Theodor-Heuss-Straße 18, D-35440 Linden
Distributor <i>Vertreiber</i>	IBP GmbH Theodor-Heuss-Straße 18, D-35440 Linden
Product Category <i>Produktart</i>	installation systems and system joints (PN 10): pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	system connector as compression connector (type M-MM) made of stainless steel for pipes made of stainless steel according to DVGW working sheet GW 541
Model <i>Modell</i>	>B< Press Inox
Test Reports <i>Prüfberichte</i>	laboratory control test: 120004061-21-2-PB from 23.11.2021 (MPM) type testing: 120003969 from 13.07.2012 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534 (01.05.2004) DVGW CERT ZP 8500 (01.01.2017) UBA BWGL-Metalle (14.05.2020) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)

70028-01-A-DE

Date of Expiry / File No. 13.07.2027 / 22-0361-WNV
Ablaufdatum / Aktenzeichen

01.06.2022 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
>B< Press Inox	diameter: 12 mm	
>B< Press Inox	diameter: 15 mm	
>B< Press Inox	diameter: 18 mm	
>B< Press Inox	diameter: 22 mm	
>B< Press Inox	diameter: 28 mm	
>B< Press Inox	diameter: 35 mm	
>B< Press Inox	diameter: 42 mm	
>B< Press Inox	diameter: 54 mm	

certified Components

zertifizierte Bauteile / Werkstoffe

Registr. No. Registr.-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
DW-5253BT0074	Sealing material for drinking water installations	TIMO 5-70/TIMO 5-70	Tecnogomma International S.p.A.

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The type testing was made with pipes made of stainless steel according to DVGW working sheet GW 541.
press contour: V